

**INDIAN INSTITUTE OF TECHNOLOGY BOMBAY.
ELECTRICAL MAINTENANCE DIVISION**

MONTHLY POWER SHUT DOWN REPORT

Month- Feb-2010 .

Date	Time From To	Areas Affected	Reason of power shutdown
01/02/10	23.30 00.15	Hostel No-10 Mess	MCB Tripped
02/02/10	23.20 23.40	Tulsi C-66	MCB Tripped
04/02/10	00.15 00.45	Vanvihar 1st , 2nd & 3rd floor.	Mains MCB Tripped
	00.15 00.45	SAC-E-Cell Room	
07/02/10	16.00 16.30	Kalpana Construction site	One phase fuse base burnt(Y phase) in Hostel No.-7 F.P.
09/02/10	17.45 17.59	Entire Campus	Charging of 500KVA Tfr-2 in Receiving station.
	01.50 01.55	Entire Campus	Power failed from TATA (line No.5)
	07.00 07.30	CESE FP	Load Diversion
ACRE FP			
13/02/10	12.30 14.50	Kalpana Construction site	Cable connection work in H-7 FP
14/02/10	24.30 01.05	Hostel No-2, 2nd wing, 2nd Floor	Problem in Main DB
16/02/10	07.30 07.45	PS Quarter No-12, A wing	Mains MCB Tripped
	21.05 21.40	Type 2B Bldg. No.-17, 4Flats	Flickering Problem in R-Phase , Fuse base burn in FP
19/02/10	16.00 17.10	MW- Bldg. No.1	Cable punctured by M/s. Lalit construction.

Date	Time From To	Areas Effected	Reason of power shutdown
20/02/10	13.00 15.30	CAD	Shutdown given for internal panel work.
	23.10 23.50	Street Lights from H-8 to Convo. Hall.	Problem in Cable.
21/02/10	10.20 10.30	Entire campus	Power failed from TATA (line No.5)
23/02/10	14.30 15.30	MW-2 Full Building	Shut down given for Electrical work carried out by M/s.Theji Electricals .
	17.00 17.15	Chemical Department	One fuse(250A)B phase Blown in LT panel in Chem Substation.
26/02/10	07.25 07.30	ACRE Substation	Load Diversion From Old Tfr to New Tfr.
28/02/10	14.45 22.15	PC Saxena Auditorium	Shut down given from FP to carry out work in LT panel by CAD section IN-charge.