

## MONTHLY POWER SHUT DOWN REPORT

Month- Jan-2010

Date: 16/02/2010

<b>Date</b>	<b>Time From To</b>	<b>Areas Effected</b>	<b>Reason of power shutdown</b>
1.10.10	17.25 18.00	M.Bldg, M.Bldg. Annex	Load Diversion ( L.T. Side)
	17.25 18.00	ACRE Substation (ACRE RSIC, CSE, Mech. Engg.	Load taken on new Transformer
20.1.10	01.00 01.30	Hostel -9 & R.No.300-310	Problem in switch board
	09.35 09.45	Entire Campus	Fault on H.T. Outdoor bus
3.01.10	07.55 08.07	Entire Campus	Change over for work of New HT Panel of ACRE S/S
6.1.10	16.00 16.30	Type-C Bldg.No.8	Flickering in Bldg .problem in R-Phase Termination.
7.1.10	15.45 16.30	Entire Campus	Power failed from TATA (line No.6)
7.1.10	17.56 19.15	Entire Campus	Power failed from TATA Both line. ( 5 & 6 No, out )
8.1.10	13.00 13.30	All Hostel Area	H.T. circuit load diversion
9.1.10	16.20 16.33	Entire Campus	Line No.5 Tripped due to monkey fault in yard
9.1.10	16.00 17.45	Energy system lab	Shutdown given for panel work
10.1.10	11.30 12.10	Entire campus	H.T. line No.5 failed from TATA Charged over on line no.6
11.1.10	13.30 13.42	Entire Hostel Area	H.T. Shutdown at ACRE S/S for load diversion
	18.30 18.38	Entire campus	H.T.No.5 failed from TATA
14.1.10	13.00 14.00	C.E.S.E.F.P.	Shutdown for termination of (M/s. Jhansi Electricas) cable 70mm – to TCS.

15.1.10	18.45	19.30	H-1 Bldg,no.9,4 rooms& H-2,25,26	Flickering in Bldg. Problem in F.P.
18.1.10	12.30	1.00	Hostel No.9 East wing.	Problem DB
20.1.10	12.30	14.50	CSRE Dept.	Cable connection work (Shutdown)
22.1.10	12.30	15.15	TCS-2 Bldg.	Shutdown for cable connection work
25.1.10	15.30	18.30	Hostel No.12 A Full wing	Cable fault (400 sq.mm ) isolated & charged
28.1.10	11.45	12.30	Chemical Dept.(Entire)	Fuse Blown in S/S
31.1.10	10.00	10.40	Ananta Bldg.lift	Problem in MCB
31.1.10	3.00	3.15	Hostel-3 Right wing II nd floor	Problem in main MCB