

## INDIAN INSTITUTE OF TECHNOLOGY BOMBAY MATERIALS MANAGEMENT DIVISION Powai, Mumbai 400076.

## Technical Specification for Syrixus 500X High Pressure Syringe Pump $RFx\ No.:\ 6100001864$

SR.No	Technical Specification	Compliance (Yes/No)	Additional Information if Any
1	Syrixus 500x High Pressure Syringe Pump		1.222
1.1	Barrel Capacity: 500 ml or more.		
1.2	Flow Range: 0.001 to 200 ml/min or more.		
1.3	Pressure Range : 345 Bar or more		
1.4	Operating Temperature Range : 5 – 40  Degree C Ambient		
1.5	Superior Operating Temperature : Facility to work up to 200 Degree C with optional accessories		
1.6	Flow Accuracy: 0.5% of the set point.		
1.7	Displacement Resolution : 31 nL/stop or better.		
1.8	Standard Pressure Accuracy : 0.5 FS.		
1.9	Wetted Material : Hastelloy/Nitronic 50		
1.10	Power: 100-220VAC, 50 or 60 Hz.		
1.11	Display : LCD Display		
1.12	Controller: Standalone keypad controller. Single controller should be able to control		

	4 individual pumps through the control cables.
1.13	Software drivers for data acquisition and supervision facilities.
1.14	Controller should have facility to program flow & pressure gradient w.r.t time
1.15	Spare: - seal kits, rupture discs (If any).
1.16	Inlet & outlet connector with manual valve
1.17	one-year warranty from date of installation.
1.18	Provide customer list and contact information of customer regarding installation in Mumbai and India